

VOC Content Test Certificate

Wednesday, 12th February 2014

Manufacturer: Merz Construction Products Ltd (13D Paul Matthews Road, Albany, Auckland NZ 0632)

Sample Description: TEKAFLEX MS 40

Date Tested: January 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	TEKAFLEX MS 40
Multipurpose construction adhesive* 70 grams per Litre as VOC content per material	12 grams per Litre as VOC content per material
The above results may be considered representative of the TEKAFLEX MS 15 product supplied by Merz Construction Products Ltd as advised by Merz Construction Products Ltd.	

*Sealants used to enhance the fire and water-proofing properties are included



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140110